# Data sheet



Figure similar

General information	
Product type designation	CPU 1515R-2 PN
Control elements	
Mode selector switch	1
Supply voltage	
Type of supply voltage	24 V DC
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
Mains/voltage failure stored energy time	5 ms
Input current	
Current consumption (rated value)	0.8 A
Inrush current, max.	2.4 A
l²t	0.02 A <sup>2</sup> ·s
Power loss	

**PNAP** 

Power loss, typ.	6.3 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
integrated (for program)	500 kbyte
• integrated (for data)	3 Mbyte
Load memory	
Plug-in (SIMATIC Memory Card), max.	32 Gbyte
Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	60 ns
for word operations, typ.	72 ns
for fixed point arithmetic, typ.	96 ns
for floating point arithmetic, typ.	384 ns
CPU-blocks	
Number of elements (total)	6 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	Number range: 1 to 59 999
• Size, max.	3 Mbyte; For non-optimized block accesses, the max. size of the DB is 64 KB
FB	
Number range	0 65 535
• Size, max.	500 kbyte
FC	
Number range	0 65 535
• Size, max.	500 kbyte
ОВ	
• Size, max.	500 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	100
<ul> <li>Number of time alarm OBs</li> </ul>	20
Number of delay alarm OBs	20
Number of cyclic interrupt OBs	20
Number of process alarm OBs	50
Number of startup OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	
• per priority class	24
h - h - A	



ounters, timers and their retentivity	
67 counter	
Number	2 048
Retentivity	
— adjustable	Yes
EC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
EC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
ata areas and their retentivity	
Retentive data area (incl. timers, counters, flags),	512 kbyte
max.	
Flag	
<ul><li>Number, max.</li></ul>	16 kbyte
<ul> <li>Number of clock memories</li> </ul>	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
Retentivity adjustable	Yes
Retentivity preset	No
Local data	
• per priority class, max.	64 kbyte; max. 16 KB per block
ddress area	
Number of IO modules	4 096; max. number of modules / submodules
/O address area	
• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
ardware configuration	
Number of IO Controllers	



Backup time Deviation per day, max.  Dereating hours counter  Number Clock synchronization  supported A salve A no A salve A no A salve A no A salve	ime of day	
Deviation per day, max.  Operating hours counter  Number  No  Interfaces  Rad S (Ethernet)  Rad S (Ethernet)  Protocol  ProFINET IO Controller  PROFINET IO Controller  Services  PROFINET IO Controller  PROFINET IO Controller  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO	Clock	
Operating hours counter  Number  Number  Supported Suppo	Backup time	6 wk; At 40 °C ambient temperature, typically
Number Clock synchronization     supported Yes     in AS, master No     in AS, slave No     on Ethernet via NTP Yes  Iterfaces Number of PROFINET interfaces 1  Interface interface types     RI 45 (Ethernet) Yes; X1     Number of ports 2     interpated switch Yes  Protocols  IP protocol Yes; IPv4 PROFINET IO Controller Yes PROFINET IO Device No SIMATIC communication Yes; Only Server Media redundancy Yes Media redundancy Yes PROFINET IO Controller Services     PG/OP communication Yes PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO communication share set for PROFINET IO, on the number of IO	<ul> <li>Deviation per day, max.</li> </ul>	10 s; Typ.: 2 s
Clock synchronization  • supported • in AS, master • in AS, slave • on Ethernet via NTP  Ves  **Interfaces  Number of PROFINET interfaces  • RJ 45 (Ethernet) • integrated switch  Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Ves • Media redundancy • Media redundancy • PROFINET IO Controller  Services  - PG/OP communication • Media redundancy • Media redundancy • Media redundancy • Media redundancy • PROFINET IO Controller  Services  - PG/OP communication • No • Media redundancy • Media redundancy • Media redundancy • PROFINET IO Controller  Services  - PG/OP communication • No • Media redundancy • Medi	Operating hours counter	
• supported • in AS, master • in AS, slave • on Ethernet via NTP  **Terfaces** Number of PROFINET interfaces  • RJ 45 (Ethernet) • Nesserial expression of the protocol expression of	• Number	16
in AS, master  in AS, slave  on Ethernet via NTP  Ves  iterfaces  Number of PROFINET interfaces  1  Interface  interface types  on J 45 (Ethernet)  on Number of ports  on Interface types  integrated switch  on Number of ports  on IP protocol  on IP protocol  on IP protocol  on PROFINET IO Controller  on PROFINET IO Device  on Madia redundancy  on Media redundancy  PROFINET IO Controller  Services  On Media redundancy  PROFINET IO Controller  Services  On Media redundancy  PROFINET IO No  on Media redundancy  PROFINET IO Controller  Services  Only Manager Auto, max. 50 nodes; only 16 are recommended, however  on MRPD  on	Clock synchronization	
in AS, slave     on Ethernet via NTP     Yes  iterfaces  Number of PROFINET interfaces  Interface In	• supported	Yes
on Ethernet via NTP      ves  Iterfaces  Number of PROFINET interfaces  Interface  Interface  RJ 45 (Ethernet)  Number of ports  integrated switch  Protocols  IP protocol  PROFINET IO Controller  PROFINET IO Device  SiMATIC communication  Open IE communication  Web server  Mo  Media redundancy  PROFINET IO Controller  Services  PG/OP communication  Yes  PROFINET IO Controller  Services  PG/OP communication  Yes  No  No  No  No  No  No  No  No  PROFINET IO Controller  Services  PG/OP communication  Yes  No  No  No  No  No  No  No  No  No  N	• in AS, master	No
Interfaces Number of PROFINET interfaces  Interface Interface types  PA J 5 (Ethernet) Number of ports Number of ports Number of ports Number of ports New Yes; IPv4 Protocols PROFINET IO Controller PROFINET IO Device No SIMATIC communication No Web server No Media redundancy PROFINET IO Controller No No Media redundancy No	• in AS, slave	No
Number of PROFINET interfaces  Interface Interface types  RJ 45 (Ethernet) Number of ports Integrated switch Ves Integrated switch Ves Protocols  IP protocol PROFINET IO Controller PROFINET IO Device No SIMATIC communication Open IE communication Ves Web server Media redundancy Ves PROFINET IO Controller Services  PG/OP communication Ves No	• on Ethernet via NTP	Yes
Interface literface types  PAJ 45 (Ethernet) Number of ports Interface switch Protocols IP protocol PROFINET IO Controller Services  PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  No	nterfaces	
Interface types  P RJ 45 (Ethernet) Number of ports Integrated switch Yes  Protocols  IP protocol PROFINET IO Controller PROFINET IO Device Simarrication Web server Mo Media redundancy PROFINET IO Controller Yes PROFINET IO Communication Yes; Only Server Open IE communication Yes PROFINET IO Controller Services  PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO	Number of PROFINET interfaces	1
Interface types  P RJ 45 (Ethernet) Number of ports Integrated switch Yes  Protocols  IP protocol PROFINET IO Controller PROFINET IO Device Simarrication Web server Mo Media redundancy PROFINET IO Controller Yes PROFINET IO Communication Yes; Only Server Open IE communication Yes PROFINET IO Controller Services  PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO	. Interface	
Number of ports  Integrated switch  Protocols  IP protocol  PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Yes  Media redundancy  PROFINET IO Controller  Services  PROFOP communication Yes  No  Services  PG/OP communication No  IRT  MRP  PROFINET  No  MRP  PROFINET  No  PROFINET  No  No  No  No  No  No  No  No  No  N	Interface types	
integrated switch  Protocols  IP protocol  PROFINET IO Controller  PROFINET IO Device  SIMATIC communication  Open IE communication  Web server  Mo  Media redundancy  PROFINET IO Controller  Services  PROFOP communication  Yes  No  Yes  PROFINET IO Controller  Services  PROFOP communication  Yes  No  No  No  No  PROFINET IO Controller  Services  PROFOP communication  No  Services  PROFOP communication  No  No  No  PROFINET No  PROFINET No  No  No  IRT  No  PROFINED  PROFINED  No  PROFINED  PROFINED  PROFINED  PROFINED  PROFINED  No  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO	• RJ 45 (Ethernet)	Yes; X1
Protocols  IP protocol PROFINET IO Controller PROFINET IO Device PROFINET IO Device SIMATIC communication Open IE communication Web server Mo Media redundancy PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  No Services  PROFINET IO Controller  Services  PROFINET IO Controller  No Services  PROFINET IO Controller  No Hadia redundancy Profinet IO Controller  No The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO	Number of ports	2
IP protocol PROFINET IO Controller PROFINET IO Device PROFINET IO Device SIMATIC communication Open IE communication Web server Mo Media redundancy PROFINET IO Controller  Services  — PG/OP communication — S7 routing — Isochronous mode — IRT — MRP — MRP — WRPD — PROFINET IO — PROFINET IO  No — No — No — No — IRT — MRP — Wes; Only Manager Auto, max. 50 nodes; only 16 are recommended, however  — MRPD — PROFIenergy — Number of connectable IO Devices, max. — Updating times  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO  PROFIED IO  PROFINET IO Controller  Yes  No  Yes  Only Manager Auto, max. 50 nodes; only 16 are recommended, however  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO	• integrated switch	Yes
PROFINET IO Controller PROFINET IO Device PROFINET IO Device SIMATIC communication Pess Open IE communication Web server Mo Media redundancy Profinet IO Controller  Services  PG/OP communication Psortional No Sortional No Isochronous mode IRT No MRP Yes; Only Manager Auto, max. 50 nodes; only 16 are recommended, however  MRPD PROFInergy No PROFlenergy No PROFlenergy No PROFlenergy No No PROFlenergy No No PROFlenergy No No PROFlenergy No No PROFINET IO Controller  Yes Profinet IO Devices, max. Fine minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO  Profinet IO Controller  Yes Pro	Protocols	
<ul> <li>PROFINET IO Device</li> <li>SIMATIC communication</li> <li>Open IE communication</li> <li>Web server</li> <li>Media redundancy</li> <li>PROFINET IO Controller</li> <li>Services</li> <li>PG/OP communication</li> <li>S7 routing</li> <li>Isochronous mode</li> <li>IRT</li> <li>MRP</li> <li>MRP</li> <li>Yes; Only Manager Auto, max. 50 nodes; only 16 are recommended, however</li> <li>MRPD</li> <li>PROFIenergy</li> <li>No</li> <li>PROFIenergy</li> <li>Number of connectable IO Devices, max.</li> <li>Updating times</li> <li>No</li> <li>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>	IP protocol	Yes; IPv4
SIMATIC communication Open IE communication Web server Web server No Media redundancy PROFINET IO Controller Services - PG/OP communication - S7 routing - Isochronous mode - IRT - MRP - MRP - MRPD - PROFIenergy - Number of connectable IO Devices, max Updating times  Yes; Only Server  Yes No Yes No Yes No Yes No Yes No Yes Only Manager Auto, max. 50 nodes; only 16 are recommended, however  Yes OH MRPD - PROFIenergy - Number of connectable IO Devices, max.  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO	PROFINET IO Controller	Yes
<ul> <li>Open IE communication</li> <li>Web server</li> <li>Media redundancy</li> <li>Yes</li> </ul> PROFINET IO Controller Services <ul> <li>— PG/OP communication</li> <li>— S7 routing</li> <li>— Isochronous mode</li> <li>— IRT</li> <li>— MRP</li> <li>— MRP</li> <li>— Yes; Only Manager Auto, max. 50 nodes; only 16 are recommended, however</li> <li>— MRPD</li> <li>— PROFlenergy</li> <li>— No</li> <li>— PROFlenergy</li> <li>— Number of connectable IO Devices, max.</li> <li>— Updating times</li> <li>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>	PROFINET IO Device	No
<ul> <li>Web server</li> <li>Media redundancy</li> <li>PROFINET IO Controller</li> <li>Services</li> <li>— PG/OP communication</li> <li>— S7 routing</li> <li>— Isochronous mode</li> <li>— IRT</li> <li>— MRP</li> <li>— MRPD</li> <li>— MRPD</li> <li>— PROFlenergy</li> <li>— No</li> <li>— PROFlenergy</li> <li>— Number of connectable IO Devices, max.</li> <li>— Updating times</li> <li>No</li> <li>Yes</li> <li>No</li> <li>Yes</li> <li>Only Manager Auto, max. 50 nodes; only 16 are recommended, however</li> <li>— MRPD</li> <li>— Yes</li> <li>Only Manager Auto, max. 50 nodes; only 16 are recommended, however</li> <li>— MRPD</li> <li>— PROFlenergy</li> <li>— Yes</li> <li>— Number of connectable IO Devices, max.</li> <li>— Updating times</li> <li>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>	SIMATIC communication	Yes; Only Server
<ul> <li>Web server</li> <li>Media redundancy</li> <li>Yes</li> </ul> PROFINET IO Controller Services <ul> <li>— PG/OP communication</li> <li>— S7 routing</li> <li>— Isochronous mode</li> <li>— IRT</li> <li>— MRP</li> <li>— MRPD</li> <li>— MRPD</li> <li>— MRPD</li> <li>— PROFlenergy</li> <li>— No</li> <li>— PROFlenergy</li> <li>— Number of connectable IO Devices, max.</li> <li>— Updating times</li> <li>No</li> <li>Yes</li> <li>No</li> <li>He minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>	Open IE communication	Yes
PROFINET IO Controller  Services		No
PROFINET IO Controller  Services	Media redundancy	Yes
Services  - PG/OP communication Yes - S7 routing No - Isochronous mode No - IRT No - MRP Yes; Only Manager Auto, max. 50 nodes; only 16 are recommended, however - MRPD No - PROFlenergy Yes - Number of connectable IO Devices, max Updating times The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO		
<ul> <li>— PG/OP communication</li> <li>— S7 routing</li> <li>— Isochronous mode</li> <li>— IRT</li> <li>— MRP</li> <li>— Wes; Only Manager Auto, max. 50 nodes; only 16 are recommended, however</li> <li>— MRPD</li> <li>— PROFlenergy</li> <li>— Number of connectable IO Devices, max.</li> <li>— Updating times</li> <li>Yes</li> <li>— The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>		
<ul> <li>S7 routing</li> <li>Isochronous mode</li> <li>No</li> <li>IRT</li> <li>MRP</li> <li>Yes; Only Manager Auto, max. 50 nodes; only 16 are recommended, however</li> <li>MRPD</li> <li>PROFlenergy</li> <li>No</li> <li>PROFlenergy</li> <li>Number of connectable IO Devices, max.</li> <li>Updating times</li> <li>No</li> <li>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>		Yes
<ul> <li>— Isochronous mode</li> <li>— IRT</li> <li>— MRP</li> <li>— Wes; Only Manager Auto, max. 50 nodes; only 16 are recommended, however</li> <li>— MRPD</li> <li>— PROFlenergy</li> <li>— Number of connectable IO Devices, max.</li> <li>— Updating times</li> <li>No</li> <li>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>		No
<ul> <li>IRT</li> <li>MRP</li> <li>Yes; Only Manager Auto, max. 50 nodes; only 16 are recommended, however</li> <li>MRPD</li> <li>PROFlenergy</li> <li>Number of connectable IO Devices, max.</li> <li>Updating times</li> <li>No</li> <li>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>		
<ul> <li>MRP</li> <li>Yes; Only Manager Auto, max. 50 nodes; only 16 are recommended, however</li> <li>MRPD</li> <li>PROFlenergy</li> <li>Number of connectable IO Devices, max.</li> <li>Updating times</li> <li>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>		
<ul> <li>MRPD</li> <li>PROFlenergy</li> <li>Number of connectable IO Devices, max.</li> <li>Updating times</li> <li>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>		Yes; Only Manager Auto, max. 50 nodes; only 16 are
<ul> <li>— PROFlenergy</li> <li>— Number of connectable IO Devices, max.</li> <li>— Updating times</li> <li>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>	— MRPD	
<ul> <li>Number of connectable IO Devices, max.</li> <li>Updating times</li> <li>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO</li> </ul>		
— Updating times  The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO		
communication share set for PROFINET IO, on the number of IO		
	opading union	communication share set for PROFINET IO, on the number of IO



1 ms to 512 ms

2. Interface	
Interface types	
• RJ 45 (Ethernet)	Yes; X2
Number of ports	1
• integrated switch	No
Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	No
PROFINET IO Device	No
SIMATIC communication	Yes; Only Server
Open IE communication	Yes
Web server	No
Media redundancy	No
·	
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
<ul> <li>Autonegotiation</li> </ul>	Yes
<ul> <li>Autocrossing</li> </ul>	Yes
Industrial Ethernet status LED	Yes
Protocols	
Number of connections	
<ul> <li>Number of connections, max.</li> </ul>	108
<ul> <li>Number of connections reserved for ES/HMI/web</li> </ul>	10
Redundancy mode	
Media redundancy	
— MRP	Yes; Manager Auto is permanently set in TIA. Max. 50 nodes are possible, 16 are recommended
— MRPD	No
<ul> <li>Switchover time on line break, typ.</li> </ul>	200 ms; PROFINET MRP
<ul> <li>Number of stations in the ring, max.</li> </ul>	50; Only 16 are recommended, however
SIMATIC communication	
S7 communication, as server	Yes
<ul> <li>S7 communication, as client</li> </ul>	No
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
<ul> <li>several passive connections per port,</li> </ul>	Yes
supported	



6AG2515-2RM00-4AB0

**☼ PNAP** 

— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; Max. 5 multicast circuits
• DHCP	No
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Web server	
• HTTP	No
• HTTPS	No
OPC UA	
OPC UA Client	No
OPC UA Server	No
Further protocols	
• MODBUS	Yes; MODBUS TCP
07	
S7 message functions Program alarms	No
Flogram diamis	INU
Test commissioning functions	
Joint commission (Team Engineering)	No
Status block	Yes; up to 8 simultaneously
Single step	No
Status/control	
<ul> <li>Status/control variable</li> </ul>	Yes
<ul> <li>Variables</li> </ul>	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
<ul><li>Number of variables, max.</li></ul>	
— of which status variables, max.	200; per job
<ul><li>of which control variables, max.</li></ul>	200; per job
Forcing	
• Forcing, variables	Peripheral inputs/outputs
<ul><li>Number of variables, max.</li></ul>	200
Diagnostic buffer	
• present	Yes
Number of entries, max.	3 200
— of which powerfail-proof	500
Traces	
Number of configurable Traces	4
Memory size per trace, max.	512 kbyte
Interrupts/diagnostics/status information  Diagnostics indication LED	



**Ö PNAP** 

• RUN/STOP LED	Yes
• ERROR LED	Yes
• MAINT LED	Yes
<ul> <li>Connection display LINK TX/RX</li> </ul>	Yes

Supported technology objects	
Motion Control	No
Controller	
<ul><li>PID_Compact</li></ul>	No
PID_3Step	No
PID-Temp	No
Counting and measuring	
High-speed counter	No

Isolation	
Isolation tested with	707 V DC (type test) and according to EN 50155 (routine test)

Standards, approvals, certificates	
Railway application	
● EN 50121-3-2	Yes; EMC for rail vehicles
● EN 50121-4	Yes; EMC for signal and telecommunications systems
● EN 50124-1	Yes; Railway applications - overvoltage category OV2; pollution degree PD2; rated surge voltage UNi = 0.5 kV; UNm = 24 V DC
● EN 50125-1	Yes; Rail vehicles - see ambient conditions
● EN 50125-2	Yes; Stationary electrical equipment - see ambient conditions
• EN 50125-3	Yes; Signal and telecommunications systems - see ambient conditions; vibrations and shocks: Application point outside of tracks (1 m to 3 m away from track)
● EN 50155	Yes; Rail vehicles - temperature class Tx, horizontal mounting position, salt spray Class ST2
● EN 61373	Yes; Rail vehicles - vibrations and shocks: Category 1 Class A/B
• Fire protection acc. to EN 45545-2	Yes; Rail vehicles - verification on request

Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	-40 °C; = Tmin (incl. condensation/frost)
<ul> <li>horizontal installation, max.</li> </ul>	70 °C; = Tmax; +85 °C for 10 min (Tx acc. to EN 50155)
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
<ul> <li>Ambient air temperature-barometric pressure- altitude</li> </ul>	Tmin Tmax at 1 080 hPa 795 hPa (-1 000 m +2 000 m)
Relative humidity	



• With condensation, tested in accordance with IEC 60068-2-38, max.

100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation

#### Resistance

#### Coolants and lubricants

Resistant to commercially available coolants and lubricants

Yes; Incl. diesel and oil droplets in the air

## Use in stationary industrial systems

— to biologically active substances according to EN 60721-3-3

— to chemically active substances according to EN 60721-3-3

— to mechanically active substances according to EN 60721-3-3

Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request

Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3);  $^{\star}$ 

Yes; Class 3S4 incl. sand, dust, \*

# Use on land craft, rail vehicles and special-purpose vehicles

— to biologically active substances according to EN 60721-3-5

— to chemically active substances according to EN 60721-3-5

— to mechanically active substances according to EN 60721-3-5

Yes; Class 5B2 mold, fungus and dry rot spores (with the exception of fauna); Class 5B3 on request

Yes; Class 5C3 (RH < 75 %) incl. salt spray acc. to EN 50155 (ST2);  $^{\star}$ 

Yes; Class 5S3 incl. sand, dust; \*

### Usage in industrial process technology

— Against chemically active substances acc. to EN 60654-4

— Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04

Yes; Class 3 (excluding trichlorethylene)

Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)

### Remark

 Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04 \* The supplied plug covers must remain in place over the unused interfaces during operation!

#### Conformal coating

 Coatings for printed circuit board assemblies acc. to EN 61086

• Protection against fouling acc. to EN 60664-3

 Electronic equipment on rolling stock acc. to EN 50155

 Military testing according to MIL-I-46058C, Amendment 7

 Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A Yes; Class 2 for high reliability

Yes; Type 1 protection

Yes; Class PC2 protective coating acc. to EN 50155:2017

Yes; Discoloration of coating possible during service life

Yes; Conformal coating, Class A

# Configuration

## Programming

Programming language



— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	No
— GRAPH	No
Know-how protection	
User program protection/password protection	Yes
Copy protection	No
Block protection	Yes
Access protection	
Protection level: Write protection	Yes
<ul> <li>Protection level: Read/write protection</li> </ul>	Yes
<ul> <li>Protection level: Complete protection</li> </ul>	Yes
Dimensions	
Width	105 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	1 100 g
Other	
Note:	for use in railway applications, also observe the product information "SIPLUS extreme RAIL" A5E37661960A, Online Support article 109736776
last modified:	10/09/2020

